7217 Roper Road NW Edmonton, Alberta T6B 3J4, Canada T: +1 (780) 438-5522 F: +1 (780) 434-8586 E: Edmonton@exova.com W: www.exova.com



# **Report Transmission Cover Page**

Bill To: Town of Inuvik Project: Lot ID: 1081737

Report To: Town of Inuvik ID: SNP 0036-2 Control Number:

Box 1160 Name: Date Received: Jul 14, 2015
2 Firth Street Location: Hidden Lake Treatment Date Reported: Jul 22, 2015

Inuvik, NT, Canada LSD: Report Number: 2026119
X0E 0T0 P.O.: 100104

Attn: Rick Campbell Acct code:

Sampled By: Terry Copeman Company: Town of Inuvik

Contact & Affiliation	Address	Delivery Commitments
Rick Campbell Town of Inuvik	2 Firth Street, Box 1160 Inuvik, Northwest Territories X0E 0T0 Phone: (867) 777-8615 Fax: (867) 777-8601 Email: rcampbell@town.inuvik.nt.ca	On [Report Approval] send (COC, Test Report) by Email - Merge Reports On [Lot Approval and Final Test Report Approval] send (Invoice) by Email - Single Report
Utilidor Town of Inuvik	2 Firth Street, Box 1160 Inuvik, Northwest Territories X0E 0T0 Phone: (867) 777-2607 Fax: (867) 777-2071 Email: utilidor@town.inuvik.nt.ca	On [Lot Approval and Final Test Report Approval] send (Invoice) by Email - Single Report
Richard Feilden Aecom - Edmonton	17203 – 103rd Avenue Edmonton, Alberta T5S 1J4 Phone: (780) 488-6800 Fax: (780) 488-2121 Email: richard.feilden@aecom.com	On [Lot Verification] send  (COA, COC) by Email - Single Report  On [Report Approval] send  (COC, Test Report) by Email - Merge Reports
Kim Wainman Town of Inuvik	2 Firth Street, Box 1160 Inuvik, Northwest Territories X0E 0T0 Phone: (867) 777-8615 Fax: (867) 777-8601 Email: kwainman@town.inuvik.nt.ca	On [Lot Approval and Final Test Report Approval] send (Invoice) by Email - Single Report

### **Notes To Clients:**

• Some trace total metal results were less than dissolved metal results for sample 1081737-1. The results were verified and are within expected measurement uncertainty.

The information contained on this and all other pages transmitted, is intended for the addressee only and is considered confidential.

If the reader is not the intended recipient, you are hereby notified that any use, dissemination, distribution or copy of this transmission is strictly prohibited.

If you receive this transmission by error, or if this transmission is not satisfactory, please notify us by telephone.

T: +1 (780) 438-5522 F: +1 (780) 434-8586 E: Edmonton@exova.com W: www.exova.com



# **Analytical Report**

Bill To: Town of Inuvik Project: Lot ID: 1081737

Report To: Town of Inuvik ID: SNP 0036-2 Control Number:

Box 1160 Name: Date Received:

Post 1760 Name: Date Received: Jul 14, 2015
2 Firth Street Location: Hidden Lake Treatment Date Reported: Jul 22, 2015
Inuvik, NT, Canada LSD: Report Number: 2026119

X0E 0T0 P.O.: 100104

Attn: Rick Campbell Acct code: Sampled By: Terry Copeman

Company: Town of Inuvik

Reference Number 1081737-1 Sample Date July 13, 2015 Sample Time NA

Sample Time N
Sample Location

Sample Description Raw Water / SNP0036-2 / 5.4°C

Sample Matrix Water

Analyte		Units	Result	Nominal Detection Limit	Guideline Limit	Guideline Comments
Inorganic Nonmetallic	Parameters					
Sulfide	Total	mg/L	< 0.002	0.002	0.05	Below AO
Organic Carbon	Total Nonpurgeable	mg/L	10.7	0.5		
Organic Carbon	Dissolved Nonpurgeable	mg/L	10.4	0.5		
Chlorine	Total	mg/L	<0.1	0.1		
Cyanide	Dissolved	mg/L	< 0.002	0.002	0.2	Below MAC
Hydrogen Sulfide	Calculated	mg/L	< 0.002			
Metals Dissolved		· ·				
Subsample	Field Filtered		Lab Filtered			
Metals Total						
Aluminum	Total	mg/L	<0.02	0.02	0.1	Below OG
Calcium	Total	mg/L	23.4	0.2		
Iron	Total	mg/L	0.14	0.05	0.3	Below AO
Magnesium	Total	mg/L	6.50	0.2		
Manganese	Total	mg/L	0.037	0.005	0.05	Below AO
Potassium	Total	mg/L	1.7	0.4		
Silicon	Total	mg/L	0.43	0.05		
Sodium	Total	mg/L	4.0	0.4	200	Below AO
Sulfur	Total	mg/L	12.9	0.3		
Mercury	Total	mg/L	<0.000005	0.000005	0.001	Below MAC
Antimony	Total	mg/L	<0.0002	0.0002	0.006	Below MAC
Arsenic	Total	mg/L	0.0005	0.0002	0.01	Below MAC
Barium	Total	mg/L	0.037	0.001	1.0	Below MAC
Beryllium	Total	mg/L	< 0.0001	0.0001		
Bismuth	Total	mg/L	< 0.0005	0.0005		
Boron	Total	mg/L	0.016	0.002	5.0	Below MAC
Cadmium	Total	mg/L	0.00001	0.00001	0.005	Below MAC
Chromium	Total	mg/L	< 0.0005	0.0005	0.05	Below MAC
Cobalt	Total	mg/L	< 0.0001	0.0001		
Copper	Total	mg/L	0.002	0.001	1.0	Below AO
Lead	Total	mg/L	<0.0001	0.0001	0.01	Below MAC
Lithium	Total	mg/L	0.003	0.001		
Molybdenum	Total	mg/L	<0.001	0.001		
Nickel	Total	mg/L	0.0014	0.0005		
Selenium	Total	mg/L	< 0.0002	0.0002	0.05	Below MAC
Silver	Total	mg/L	< 0.00001	0.00001		

Terms and Conditions: www.exova.com/about/terms-and-conditions

T: +1 (780) 438-5522 F: +1 (780) 434-8586 E: Edmonton@exova.com W: www.exova.com



# **Analytical Report**

Bill To: Town of Inuvik Project: Lot ID: 1081737

ID: SNP 0036-2 Report To: Town of Inuvik Control Number:

Acct code:

Box 1160 Name: Date Received:

Jul 14, 2015 2 Firth Street Location: Hidden Lake Treatment Date Reported: Jul 22, 2015 LSD: Inuvik, NT, Canada Report Number: 2026119

X0E 0T0 P.O.: 100104

Sampled By: Terry Copeman Company: Town of Inuvik

Attn: Rick Campbell

**Reference Number** 1081737-1 Sample Date July 13, 2015 NA

Sample Time **Sample Location** 

**Sample Description** Raw Water / SNP0036-2 / 5.4°C

Sample Matrix Water

		Cample Matrix	Water			
Analyte		Units	Result	Nominal Detection Limit	Guideline Limit	Guideline Comments
Metals Total - Continued						
Strontium	Total	mg/L	0.077	0.001		
Thallium	Total	mg/L	< 0.00005	0.00005		
Tin	Total	mg/L	< 0.001	0.001		
Titanium	Total	mg/L	0.0007	0.0005		
Uranium	Total	mg/L	< 0.0005	0.0005	0.02	Below MAC
Vanadium	Total	mg/L	0.0002	0.0001		
Zinc	Total	mg/L	0.004	0.001	5.0	Below AO
Microbiological Analysis						
Total Coliforms	Membrane Filtration	CFU/100 mL	24	1	0	Above MAC
Escherichia coli	Membrane Filtration	CFU/100 mL	<1	1	0	Below MAC
Physical and Aggregate P	Properties					
Solids	Total Dissolved	mg/L dried at 180 °C	92	7	500	Below AO
Colour	Apparent, Potable	Colour units	25	5	15	Above AO
Turbidity		NTU	3.6	0.1	0.1	Above OG
Solids	Total Suspended	mg/L	<1	1		
Routine Water						
рН			7.28		6.5 - 8.5	Within AO
Temperature of observed pH		°C	22.0			
Electrical Conductivity	at 25 °C	uS/cm	183	1		
Calcium	Dissolved	mg/L	24	0.2		
Magnesium	Dissolved	mg/L	5	0.2		
Sodium	Dissolved	mg/L	5	0.4	200	Below AO
Potassium	Dissolved	mg/L	<4	0.4		
Iron	Dissolved	mg/L	<0.1	0.01	0.3	Below AO
Manganese	Dissolved	mg/L	< 0.05	0.005	0.05	Below AO
Chloride	Dissolved	mg/L	4.7	0.4	250	Below AO
Fluoride		mg/L	0.10	0.05	1.5	Below MAC
Nitrate - N		mg/L	0.01	0.01	10	Below MAC
Nitrite - N		mg/L	< 0.005	0.005	1	Below MAC
Nitrate and Nitrite - N		mg/L	0.01	0.01	10	Below MAC
Sulfate (SO4)	Dissolved	mg/L	40.6	0.9	500	Below AO
Hydroxide		mg/L	<5	5		
Carbonate		mg/L	<6	6		
Bicarbonate		mg/L	62	5		

Report Number: 2026119

# **Analytical Report**

Bill To: Town of Inuvik Project: Lot ID: 1081737

Report To: Town of Inuvik ID: SNP 0036-2 Control Number:

Box 1160 Name:

Date Received: Jul 14, 2015 2 Firth Street Location: Hidden Lake Treatment Date Reported: Jul 22, 2015 LSD: Inuvik, NT, Canada

X0E 0T0 P.O.: 100104

Sampled By: Terry Copeman Company: Town of Inuvik

Attn: Rick Campbell

**Reference Number** 1081737-1 Sample Date July 13, 2015 NA

Sample Time **Sample Location** 

**Sample Description** 

Acct code:

Raw Water / SNP0036-2 / 5.4°C

Sample Matrix Water

		Sample Matrix	vvater			
Analyte		Units	Result	Nominal Detection Limit	Guideline Limit	Guideline Comments
Routine Water - Continue	ed					
P-Alkalinity	as CaCO3	mg/L	<5	5		
T-Alkalinity	as CaCO3	mg/L	51	5		
Total Dissolved Solids	Calculated	mg/L	110	1	500	Below AO
Hardness	Dissolved as CaCO3	mg/L	80			
Ionic Balance	Dissolved	%	94			
Trihalomethanes Screen	- Water					
Chloroform		mg/L	< 0.001	0.001	0.1	Below MAC
Bromodichloromethane		mg/L	< 0.001	0.001	0.1	Below MAC
Dibromochloromethane		mg/L	< 0.001	0.001	0.1	Below MAC
Bromoform		mg/L	< 0.001	0.001	0.1	Below MAC
Total Trihalomethanes		mg/L	< 0.001	0.001	0.1	Below MAC
Trihalomethanes - Surro	gate Recovery					
Dibromofluoromethane	EPA Surrogate	%	112	86-118		
Toluene-d8	EPA Surrogate	%	105	85-115		
Bromofluorobenzene	EPA Surrogate	%	90	86-115		

Approved by:

Consulting Scientist



# **Methodology and Notes**

Bill To: Town of Inuvik Project: Lot ID: 1081737

Report To: Town of Inuvik ID: SNP 0036-2 Control Number:

Box 1160 Name:

Date Received: Jul 14, 2015 2 Firth Street Location: Hidden Lake Treatment Date Reported: Jul 22, 2015 Inuvik, NT, Canada LSD: Report Number: 2026119

X0E 0T0 P.O.: 100104 Attn: Rick Campbell Acct code:

Sampled By: Terry Copeman Company: Town of Inuvik

Method of Analysis			
Method Name	Reference	Method Date Analysis Location Started	
Alkalinity, pH, and EC in water	APHA	Alkalinity - Titration Method, 2320 B 14-Jul-15 Exova Edmont	on
Alkalinity, pH, and EC in water	APHA	Conductivity, 2510 B 14-Jul-15 Exova Edmont	on
Alkalinity, pH, and EC in water	APHA	pH - Electrometric Method, 4500-H+ B 14-Jul-15 Exova Edmont	on
Anions (Routine) by Ion Chromatography	APHA	lon Chromatography with Chemical 17-Jul-15 Exova Edmont Suppression of Eluent Cond., 4110 B	on
Approval-Edmonton	APHA	Checking Correctness of Analyses, 1030 14-Jul-15 Exova Edmont E	on
Carbon Organic (Dissolved) in water (DOC)	APHA	High-Temperature Combustion Method, 17-Jul-15 Exova Edmont 5310 B	on
Carbon Organic (Total) in water (TOC)	APHA	High-Temperature Combustion Method, 14-Jul-15 Exova Edmont 5310 B	on
Chloride in Water	APHA	Automated Ferricyanide Method, 4500-Cl- 17-Jul-15 Exova Edmont E	on
Chlorine (Total) in water	APHA	DPD Colorimetric Method, 4500-Cl G 15-Jul-15 Exova Edmont	on
Coliforms - Membrane Filtration	APHA	E. Coli - MF Partition Procedures, 9222 G 15-Jul-15 Exova Calgary	,
Coliforms - Membrane Filtration	APHA	Standard Total Coliform Membrane Filter 15-Jul-15 Exova Calgary Procedure, 9222 B	
Colour (Apparent) in water	APHA	Visual Comparison Method, 2120 B 21-Jul-15 Exova Edmont	on
Cyanide (Dissolved) in water	Alta. Env. Method	Cyanide, Simple Extractable (Automated 20-Jul-15 Exova Edmont Pyridine-Barbituric Acid Colorimetric Method), 06608L	on
Mercury (Total) in water	EPA	Mercury in Water by Cold Vapor Atomic 16-Jul-15 Exova Edmont Fluorescence Spectrometry, 245.7	on
Metals ICP-MS (Total) in water	APHA/USEPA	Metals By Inductively Coupled 14-Jul-15 Exova Edmont Plasma/Mass Spectrometry, APHA 3125 B / USEPA 200.2, 200.8	on
Metals Trace (Dissolved) in water	APHA	Hardness by Calculation, 2340 B 17-Jul-15 Exova Edmont	on
Metals Trace (Dissolved) in water	APHA	Inductively Coupled Plasma (ICP) 17-Jul-15 Exova Edmont Method, 3120 B	on
Metals Trace (Total) in water	APHA	Inductively Coupled Plasma (ICP) 14-Jul-15 Exova Edmont Method, 3120 B	on
Solids Dissolved (Total, Fixed and Volatile)	APHA	Total Dissolved Solids Dried at 180 C, 17-Jul-15 Exova Edmont 2540 C	on
Solids Suspended (Total, Fixed and Volatile)	APHA	Total Suspended Solids Dried at 103- 20-Jul-15 Exova Edmont 105'C, 2540 D	on
Sulfide in water	APHA	Gas Dialysis, Automated Methylene Blue 15-Jul-15 Exova Edmont Method, 4500-S2- E	on
ΓΗM - Water	US EPA	US EPA method, 524 16-Jul-15 Exova Calgary	
Turbidity in Water	APHA	Turbidity - Nephelometric Method, 2130 B 21-Jul-15 Exova Edmont	.on

<sup>\*</sup> Reference Method Modified



# **Methodology and Notes**

Bill To: Town of Inuvik Project: Lot ID: 1081737

Report To: Town of Inuvik ID: SNP 0036-2 Control Number:

Box 1160 Name: Date Received:

Jul 14, 2015 Hidden Lake Treatment 2 Firth Street Location: Date Reported: Jul 22, 2015 Inuvik, NT, Canada LSD: Report Number: 2026119

X0E 0T0 P.O.: 100104

Attn: Rick Campbell Acct code:

Sampled By: Terry Copeman Company: Town of Inuvik

### References

Alta. Env. Method Alberta Environment Method

APHA Standard Methods for the Examination of Water and Wastewater

**US EPA** US Environmental Protection Agency Test Methods

### Guidelines

Guideline Description Health Canada GCDWQ

Guideline Source Guidelines for Canadian Drinking Water Quality, Health Canada, October 2014

Guideline Comments MAC = Maximum Acceptable Concentration

AO = Aesthetic Objective

OG = Operational Guideline for Water Treatment Plants

Refer to Health Canada GCDWQ for complete guidelines and additional drinking water information at www.hc-sc.gc.ca

### Comments:

• Some trace total metal results were less than dissolved metal results for sample 1081737-1. The results were verified and are within expected measurement uncertainty.

> The comparison of test results to guideline limits is provided for information purposes only. This is not to be taken as a statement of conformance / nonconformance to any guideline, regulation or limit. The data user is responsible for all conclusions drawn with respect to the data and is advised to consult official regulatory references when evaluating compliance.

Please direct any inquiries regarding this report to our Client Services group. Results relate only to samples as submitted.

The test report shall not be reproduced except in full, without the written approval of the laboratory.